

1 - GENERAL

1.01 SUMMARY

A. Section includes: Entrance floor mats and frames, including fibered modular tile entrance systems

B. Related requirements:

1. Drawings and General Provisions of the Contract (including General and Supplementary Conditions and Division 1 References Section)
2. Section 03: Concrete (subfloors)
3. Section 06: Wood (subfloors)
4. Section 07: Thermal and moisture protection

1.02 REFERENCE STANDARDS

A. ASTM International,

1. C 1028 Standard Test Method for Determining the Static Coefficient of Friction of Ceramic Tile and Other Like Surfaces by the Horizontal Dynamometer Pull-Meter Method
2. D 2859 Standard Test Method for Ignition Characteristics of Finished Textile Floor Covering Materials
3. E 662 Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials

B. Other referenced documents

1. Consumer Products Safety Commission (CPSC) FF 1-70: Pill Test
2. Department of Commerce (DOC) FF 1-70: Pill Test

1.03 ADMINISTRATIVE REQUIREMENTS

A. Coordination: Install entrance matting after finishing operations, including painting and ceiling operations, have been completed.

B. Preinstallation Meetings: Meet to confirm project requirements, substrate conditions, manufacturer's installation instructions and warranty requirements in compliance with Division 1 requirements.

1.04 ACTION SUBMITTALS

A. General: Submit listed submittals in accordance with Conditions of the Contract and Division 1 Submittal Procedures.

B. Product Data: For specified products, submit latest edition of product supplier's technical specifications data (available from the manufacturer).

C. Shop Drawings: Submit shop drawings showing layout, profiles, and product components.

D. Samples: Submit selection and verification samples showing the required finishes, colors, designs, and textures for flooring, as well as samples of adhesives and applicable accessories such as nosing, frames, etc.

1.05 INFORMATION SUBMITTALS

A. Test and Evaluation Reports

1. Product test reports: As required by Conditions of the Contract and Division 1 Regulatory Requirements Section, submit test certificates from an independent

test laboratory showing compliance with specified performance characteristics and physical properties.

2. Compatibility and adhesion test reports: Submit test reports confirming adhesive's effectiveness with the product(s) specified.

B. Manufacturer Instructions: For specified products, submit latest editions of product supplier's installation and cleaning & maintenance instructions (available from the manufacturer).

1.06 CLOSEOUT SUBMITTALS

A. Warranty documentation: For specified products and accessories, submit product supplier's warranty documents (available from the manufacturer).

1.07 QUALITY ASSURANCE

A. Installer: Installer shall be highly experienced in performing work of this section, having previously done fiber modular tile installation work similar to that required for this project.

B. Testing Agency: Agency(ies) shall be independent and qualified to perform the specified product tests.

1.08 DELIVERY, STORAGE, AND HANDLING

A. General: Comply with Division 1 Product Requirements Section

B. Delivery and Acceptance Requirements: Comply with the product supplier's ordering and lead time requirements to avoid construction delays, and to allow material to acclimatize as required in the specified product's installation instructions. Accept delivery of materials only if they are in unopened, undamaged packaging that bears the name and brand of the manufacturer/product supplier, project identification, and shipping and handling instructions.

C. Storage and Handling Requirements: Store material -- including any adhesive and accessories -- in the original packaging (as delivered) in areas that are enclosed and weather tight with the permanent HVAC system set at a temperature of between 65°F and 80°F for a minimum of 48 hours prior to commencement of installation. In addition, comply with storage and handling requirements listed on product packaging, and described in the latest edition of the product's installation instructions (available from the manufacturer).

1.09 AMBIENT SITE CONDITIONS

The permanent HVAC system shall be operational and set at a temperature of between 65°F and 80°F for a minimum of 48 hours prior to commencement of installation, during the time of installation, and for 48 hours after installation has been completed. Thereafter, minimum temperature shall be 55°F.

2 - PRODUCTS

2.01 MANUFACTURERS

A. Supplier: Centaur Floor Systems, LLC, 135 Chapala St. Santa Barbara, CA., 800 536 9007, fax 805 957 0125, email, info@centaurfloors.com.

B. Substitutions: no substitutions permitted.

[Specifier note: edit this paragraph to suit project requirements. If substitutions are permitted, edit text. Add text to refer to Division 1 Project Requirements (Product Substitutions Procedures) Section.]

C. Product: Slant Tile

Construction: 100% solution-dyed polypropylene fiber with bitumen backing Tile size: 19 11/16" x 19 11/16" square

Case pack: 20 tiles per case (54 square feet)

Thickness: 3/8" Weight: 131 ounces/square yard

Colors: [Charcoal] [Black Walnut] [Lichen] [Gray] [Bronze] [Spruce] [Blue] [Cranberry] [Beige] [Espresso]

D. Performance: Physical properties of the entrance matting shall conform to the following minimums:

Slant Tile Safety

Surface flammability ASTM D2859 Pass (equal to CPSC FF 1-70 and DOC FF 1-70) Smoke density ASTM E662 248 (flaming mode) Performance

Slip resistance ASTM C1028 0.63 wet; 0.65 dry

2.02 ACCESSORY PRODUCTS

A. Adhesive: Architect to specify adhesive and trowel notch size per the latest edition of the installation instructions (available from the manufacturer).

B. Other:

1. Aluminum framing: specify as recommended by Mats Inc.

2. Ramp-Flex PVC transition: specify as recommended by the manufacturer.

3 - EXECUTION

3.01 EXAMINATION

A. Overall: Follow guidelines laid out in Division 01, Section 01 71 00 - Examination and Preparation as well as Section 01 43 00 - Quality Assurance.

B. Verification of Conditions: Subfloors shall be clean and dry. Inspect all substrates and subfloors for proper tolerances, and report any discrepancies to the general contractor in writing.

C. Preinstallation Measurements: Verify actual measurement by field measuring before any onsite cutting, if applicable. To avoid construction delays, coordinate field measurements based upon construction progress.

D. Evaluation and Assessment: See the state requirements for the project location.

3.02 SURFACE PREPARATION

A. Follow guidelines laid out in Division 01, Section 01 71 00 – Examination and Preparation.

B. Concrete subfloors: Where concrete subfloors are present, all work required to put the concrete subfloor in acceptable condition shall be the responsibility of the general contractor. See the state requirements for the project location.

3.03 INSTALLATION

- A. Follow Division 01 relevant guidelines, and the latest edition of the manufacturer's installation instructions (available from the manufacturer). Lay tile from center marks established with principal walls or general entrance area, discounting minor offsets, so that the tiles at opposite edges of flooring area are of equal width. Adjust as necessary to avoid use of cut widths less than 1/2 tile at room perimeters. Begin in center and install the corner of the first tile with the cross of the caulk center line. Quarter-turn tiles using directional arrows as marked on the underside of the tile. When done properly, directional arrows printed on the back of each tile should point in two directions only. Do not quarter-turn haphazardly, as the resulting pattern may not exactly match, and this is noticeable, particularly in larger areas. Coordinate installation with adjacent work to ensure proper clearances and to prevent tripping hazards.
- B. Interface with Other Work: Contact Mats Inc. for suitable transition material, which will vary by application (e.g. recessed, wall-to-wall, etc.).
- C. Sizes: Where not indicated otherwise, provide single unit for each mat installation, but do not exceed manufacturer's maximum size recommendation for units intended for removal and cleaning. Where possible, verify sizes by field measurement before shop fabrication.

3.04 CLEANING

- A. General: Clean up job site, including sweeping or dust mopping the floor to remove all dirt or grit, and put all waste in general contractor's dumpster. Follow overall cleaning guidelines described in Division 01.
- B. Initial Maintenance: Conduct a full initial maintenance following the latest edition of the manufacturer's maintenance instructions (available from the manufacturer). Instruct owner's cleaning staff in proper maintenance procedures.

3.05 CLOSEOUT ACTIVITIES

Follow state requirements and Division 01 Section 01 76 00 – Protecting Installed Construction and Section 01 78 00 - Closeout Submittals requirements for these activities.

END OF SECTION

© 2009 Centaur Floor Systems, LLC. All Rights Reserved.

A copyright license to reproduce this specification is granted to non-manufacturing architects, specification writers, and designers.

TECH DATA: (SHOWS LEED INFO)

Technical Data for Slant Tile

Product Description

Material 100% solution-dyed UV stabilized polypropylene fibers Backing Bitumen
Tile Size 19-11/16" x 19-11/16" (50 cm x 50 cm) - approximately 2.7 sq ft per tile
Case Pack 20 tiles per case - 54 sq ft per case Technical Specifications Test
Requirement Slant Tile Product Dimensions Pile height ISO 1776 In inches 1/8"
Total height ISO 1776 In inches 3/8" Pile weight ISO 8543 In ounces per square
yard 33.9 oz/sq yd Total weight ISO 8543 In ounces per square yard 131 oz/sq
yd Safety Surface flammability ASTM D2859 CPSC FF 1-70 Test specimen must
be greater than 1" in at least 7 of 8 specimens tested Passes Performance
Sound insulation ISO 140-8 In decibels (dB) > 24 dB Static electrical propensity
EN 1815 Antistatic: less than 2 kilovolts (kV) < 2 kV Color Fastness To light ISO
105 B02 1 = considerable change; 5 = negligible or no change 5 To water ISO
105 E01 1 = considerable change; 5 = negligible or no change 4 – 5. To
shampoo BS 1006 1 = considerable change; 5 = negligible or no change 5. To
rubbing wet and dry ISO 105 x 12 1 = considerable change; 5 = negligible or no
change Wet: 4 - 5; Dry: 4 - 5

LEED

MR Credit 4 LEED-NC v. 3 For 1 - 2 points: \$ value of all materials = min.
average 10% recycled content 15% recycled (pre-consumer) IEQ Credit 4.1
LEED-NC v. 3 For 1 point: low-emitting adhesive with a VOC of 50 g/L or less for
indoor carpet adhesive Release-Bond VOC: 0 g/L

Centaur

Floor Systems

135 Chapala Street
Santa Barbara, CA 93101
Toll-Free: 1-800-536-9007
Ph: 805-957-0182
Fax: 805-957-0125
info@centaurlfloors.com
www.centaurlfloors.com

